



Certificate No. : T-0071

**ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION**

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382




E-mail : erda@erda.org

Web : http://www.erda.org



**TEST REPORT**

SHEET 1 OF 9

<b>NAME &amp; ADDRESS OF CUSTOMER</b> <b>ALLIANZ TRANSFORMERS PVT. LTD.</b> Plot No. 11 & 12, Dewan Udyog Nagar, Chintupada, Mahim Village, Palghar (West), Dist. – Palghar, Maharashtra - 401 404.	<b>REPORT NO.:</b> RP-1516-023432 <b>DATE:</b> 02.09.2015	
	<b>CUSTOMER REF. No.:</b> Nil	<b>DATED:</b> 21.08.2015
	<b>DATE OF SAMPLE RECEIPT:</b> 20.08.2015	<b>DATE OF TESTING:</b> 21.08.2015 to 28.08.2015
	<b>SAMPLE DESCRIPTION</b> <b>630 kVA TRANSFORMER</b> 22000/433 Volts, 16.53/840 Amps, Oil filled, Vector Group: Dyn-11 Further details as per sheet No. 3 of 9	
<b>SAMPLE IDENTIFICATION</b> <b>ERDA Sample Code No.:</b> ERDA-00103771 <b>TYPE:</b> Outdoor <b>SERIAL NO.:</b> 021 <b>YEAR OF MFG.:</b> 2015 <b>DRAWING NO.:</b> AT/NP/630/22/1, AT/GA/630/22/1, AT/IC/630/22/1, AT/TD/630/22/1.		
<b>TEST DETAILS</b> Ability to withstand dynamic effects of short circuit (Cl. No. 4.2)	<b>TEST SPECIFICATIONS</b> As per customer's requirement, test procedure followed as per IS 2026 (Part 5): 2011	
<b>ENCLOSURES:</b> NUMBER OF OSCILLOGRAMS : Ten NUMBER OF PHOTOGRAPH : One NUMBER OF TEST CIRCUIT DIAGRAM : One NUMBER OF DRAWINGS : Four		
<b>REMARKS:</b> The sample <b>conforms</b> to the requirements of ability to withstand dynamic effects of short circuit as specified by customer.		
 <b>PREPARED BY</b>	 <b>CHECKED BY</b>	 <b>(YASHINKHAN I. PATHAN)</b> <b>APPROVED BY</b>

**Note:** 1. This report relates only to the particular sample received in good condition for testing at ERDA.

2. This report cannot be reproduced in part under any circumstances.

3. Publication of this report requires prior permission in writing from Director, ERDA.

4. Only test asked for by customer have been carried out.

5. In case of any dispute, Vadodara will be the exclusive jurisdiction & shall be construed as where the cause has arisen.

**Caution :** ERDA is not responsible for the authenticity of photocopied or reproduced test reports.

ERDA provides support to customers for verification of the authenticity of test reports issued by ERDA.



TE 1730160